

Review on Transformer less PV Grid Connected Full-Bridge Inverter Topology with Constant Common-Mode Voltage

Monika Pusatkar¹ and Sneha Tibude²

Students, Department of Electrical Engineering¹

Assistant Professor Department of Electrical Engineering²

Abha Gaikwad College of Engineering and Technology, Nagpur, India

Abstract: *Transformer less inverters are widely used in grid-tied photovoltaic (PV) generation systems, due to the benefits of achieving high efficiency and low cost. Various transformer less inverter topologies have been proposed to meet the safety requirement of leakage currents, such as specified in the VDE-4105 standard. In this thesis, a family of H6 transformer less inverter topologies with low leakage currents is proposed, and the intrinsic relationship between H5 topology, highly efficient and reliable inverter concept (HERIC) topology, and the proposed H6 topology has been discussed as well. One of the proposed H6 inverter topologies is taken as an example for detail analysis with operation modes and modulation strategy. The power losses and power device costs are compared among the H5, the HERIC, and the proposed H6 topologies. A universal prototype is built for these three topologies mentioned for evaluating their performances in terms of power efficiency and leakage currents characteristics. Experimental results show that the proposed H6 topology and the HERIC achieve similar performance in leakage currents, which is slightly worse than that of the H5 topology, but it features higher efficiency than that of H5 topology*

Keywords: Photovoltaic (PV), highly efficient and reliable inverter concept (HERIC)

REFERENCES

- [1] L. Zhang, K. Sun, Y. Xing and M. Xing, "H6 Transformerless Full-Bridge PV Grid-Tied Inverters," in IEEE Transactions on Power Electronics, vol. 29, no. 3, pp. 1229-1238, March 2014, doi: 10.1109/TPEL.2013.2260178.
- [2] L. Zhang, K. Sun, Y. Xing and M. Xing, "H6 Transformerless Full-Bridge PV Grid-Tied Inverters," in IEEE Transactions on Power Electronics, vol. 29, no. 3, pp. 1229-1238, March 2014, doi: 10.1109/TPEL.2013.2260178.
- [3] H. Wang, S. Burton, Y. Liu, P. C. Sen and J. M. Guerrero, "A systematic method to synthesize new transformer less full-bridge grid-tied inverters," 2014 IEEE Energy Conversion Congress and Exposition (ECCE), Pittsburgh, PA, 2014, pp. 2760-2766, doi: 10.1109/ECCE.2014.6953772.
- [4] Y. Dai, W. Li, C. Zhou and S. Zhuang, "Research on transformerless dual-buck full-bridge grid-connected inverter with H5-type for PV systems," in IET Power Electronics, vol. 12, no. 1, pp. 44-50, 12 1 2019, doi: 10.1049/iet-pel.2018.5196.
- [5] J. Fang, M. Shi, H. Xiao and R. Wang, "A Zero-Voltage-Transition H5-Type Transformer less Photovoltaic Grid-Connected Inverter," in IEEE Access, doi: 10.1109/ACCESS.2019.2946976.
- [6] Velasco de la Fuente, D; Garcera, G; Figueres, E; Guacaneme, J. "Reconfigurable control scheme for a PV micro inverter working in both grid connected and island modes," IEEE Trans. Industrial Electronics, 2012.
- [7] Jmjun Liu; Jun Yang; Zhaoan Wang "A New Approach For Single-Phase Harmonic Current Detecting And Its Application in a Hybrid Active Power Filter," IEEE conf., 1999.
- [8] B. Singh, V. Verma, "Selective compensation of power-quality problems through active power filter by current decomposition" IEEE Trans. Power delivery, vol. 23, no. 2, April 2008.
- [9] Guohong Zeng; Rasmussen, T.W; Lin Ma; Teodorescu, R., "Design and control of LCL-filter with active damping for Active Power Filter," IEEE International Symposium on Industrial Electronics, pp. 2657-2562, 2010.
- [10] S. Mekhilef, "Performance of grid connected inverter with maximum power point tracker and power factor control," International Journal of Power Electronics, vol. 1, pp. 49-62, 2008.



- [11] S.Mekh Femia, N.; Petrone, G; Spagnuolo, G; Vitelli, M., "A Technique for Improving P&O MPPT Performances of Double-Stage Grid-Connected Photovoltaic Systems," IEEE Trans. Industrial Electronics, vol. 56, pp. 4473-4482, 2009.
- [12] M. G. Villalava, j. r. Gazoli, E. Ruppert F., "Modelling and circuit based simulation of Photovoltaic arrays" Brazilian Journal of Power Electronics, vol 14, no.4, pp. 35-45, 2009
- [13] B. Crowhurst, E.F. El-Saadany, L. El Chaar and L.A. Lamont "Single-Phase Grid-Tie Inverter Control Using DQ Transform for Active and Reactive Load Power Compensation," IEEE conf., PECON, Malaysia, 2010.