IJARSCT
International Journal of Advanced Research in Science, Communication and Technology
International Open-Access, Double-Blind, Peer-Reviewed, Refereed, Multidisciplinary Online Journal
ISSN: 2581-9429
Volume 6, Issue 3, November 2026
Impact Factor: 8.2

Design and Development of Stair Lift

Mallikarjun G B[1], Yathish R[2], Siddaraju M[3], Prasad C L[4], Sagar CM[5]
[1]Assist. Professor, Dept of Mechanical Engineering
[2,3,4,5] Students, Dept of Mechanical Engineering
Kalpataru Institute of Technology, Tiptur, Karnataka.

Abstract: *This project focuses on the mechanical design and development of an automated motorized stair lift to assist elderly and mobility-impaired individuals across multi-level buildings. The primaryobjective is to create a safe, cost-effective, and user-friendly mobility solution that operateson straight or curved staircases without requiring invasive architectural modifications. The mechanical architecture utilizes a robust aluminum or steel track securely mounted to the stair treads, supporting a load-bearing carriage assembly. Propulsion is achieved through a high-torque direct-current (DC) electric motor coupled with a rack-and-pinion drive system for smooth, controlled vertical transit. Continuous and reliable power is ensured via onboard rechargeable batteries, which also provide uninterrupted operation during primary power grid failures. The control system incorporates ergonomic armrest switches and wireless remote pendants located at the terminal landings for convenient call-and-send functionality. Advanced safety features include sensitive mechanical obstacle-detection edges on the footrest and carriage to instantly halt motion upon encountering blockages. Emergency redundancy is maintained through automatic over-speed governors, mechanical spring-applied brakes, and physical limit switches to prevent terminal over-travel. Ergonomic considerations feature a swiveling seat, foldable armrests, and a retractable footrest to maximize clearance and ease of transfer for the user. Ultimately, the developed prototype bridges a crucial accessibility gap, demonstrating high structural reliability, fail-safe redundancy, and enhanced independent living.*

Keywords: Core System , Mechanical Components . Engineering & Design , Saft & Control

I. INTRODUCTION

In modern society, multi-level residential homes, commercial buildings, and public spaces offer architectural challenges for individuals with limited mobility. Staircases, which are essential structural components of multi-story buildings, frequently become physical barriers for the elderly, physically injured, or individuals with neuromuscular impairments. While architectural retrofits such as elevators or wide inclined ramps provide alternative solutions, they are often cost-prohibitive, structurally invasive, and impractical for existing residential layouts. Consequently, there is a critical need for an assistive mobility device that is compact, retrofittable, and economically viable.

The stair lift (or motorized stair climber) serves as an effective engineering solution designed to bridge this accessibility gap. By mounting a guided rail system directly onto the stair treads rather than supporting walls, a stair lift enables users to safely and comfortably traverse between levels while seated.

This project focuses on the comprehensive design, mechanical modeling, and prototype development of a motorized stair lift system. The core engineering objectives of this work include:

Structural Integration: Designing a robust track and load-bearing carriage capable of safely supporting varying user weights.

Efficient Propulsion: Implementing a reliable drive mechanism (such as a rack-and-pinion system coupled with a high-torque DC motor) to ensure smooth vertical translation.

Fail-Safe Redundancy: Integrating multi-layered safety features, including mechanical obstacle sensors, over-speed governors, and emergency braking systems to guarantee user safety under all operating conditions.

Copyright to IJARSCT
www.ijarsct.co.in
DOI: 10.48175/IJARSCT-40811

IJARSCT
International Journal of Advanced Research in Science, Communication and Technology
International Open-Access, Double-Blind, Peer-Reviewed, Refereed, Multidisciplinary Online Journal
ISSN: 2581-9429 Volume 6, Issue 3, November 2026 Impact Factor: 8.2

Ultimately, this project highlights the integration of mechanical, electrical, and ergonomic principles to create a dependable assistive technology that fosters independence and improves the quality of life for mobility-impaired individuals.

II. LITERATURE REVIEW

1. Evolution of Assistive Mobility Devices

Early approaches to multi-level accessibility relied heavily on home elevators and vertical platform lifts. However, studies by Smith et al. (2018) highlight that conventional elevators require extensive structural modifications, high installation costs, and dedicated spatial footprints, making them impractical for standard residential homes. This led to the evolution of inclined transit systems, particularly stair lifts, which utilize existing staircase structures to provide cost-effective vertical mobility without altering building architecture.

2. Drive Mechanisms and Propulsion Systems

Research into mechanical propulsion for inclined lifts heavily emphasizes reliability and smooth transit. According to Kumar and Rao (2020), rack-and-pinion drive systems are the industry standard for stair lifts due to their positive engagement, precise control, and ability to prevent slipping on steep inclines. Furthermore, literature on actuation highlights the integration of high-torque direct-current (DC) motors paired with reduction gearboxes. This combination ensures smooth acceleration, gradual deceleration, and precise stopping at terminal landings.

3. Power Management and Energy Redundancy

Uninterrupted power supply (UPS) integration is a critical theme in assistive device literature. Johnson & Patel (2019) analyzed safety failures in motorized transport and concluded that relying solely on grid power introduces severe safety hazards during blackouts. Modern literature strongly advocates for onboard rechargeable DC battery packs (such as Sealed Lead-Acid or gel cells). These batteries maintain continuous operation during grid failures and are typically trickle-charged automatically when the lift is docked at the parking stations.

4. Safety Architecture and Fail-Safe Redundancy

Safety is the most widely discussed aspect in academic and industrial literature regarding stair lifts. Williams et al. (2021) emphasized that assistive devices must feature multi-layered redundancy to account for mechanical or electrical malfunctions. Key systems highlighted in safety literature include:

Obstacle Sensors: Contact switches and optical sensors on the footrest to instantly halt movement if toys, pets, or debris obstruct the path.

Over-Speed Governors: Mechanical centrifugally-activated brakes that engage if the descent speed exceeds safe limits, protecting the user from free-fall hazards.

Limit Switches: Physical and electronic micro-switches to prevent over-travel past the top and bottom landings.

5. Ergonomics and User-Centric Design

Ergonomic evaluations of mobility aids focus on transfer comfort and spatial optimization. Studies by Anderson (2022) stress that stair lifts must feature swiveling seats and foldable armrests/footrests. This ensures that when the lift is parked at a landing, it does not completely block the staircase for other able-bodied members of the household, striking a balance between accessibility and residential convenience.

III. METHODOLOGY

The development of the motorized stair lift follows a systematic engineering design cycle, broken down into five primary phases:

IJARSCT
International Journal of Advanced Research in Science, Communication and Technology
International Open-Access, Double-Blind, Peer-Reviewed, Refereed, Multidisciplinary Online Journal
ISSN: 2581-9429 Volume 6, Issue 3, November 2026 Impact Factor: 8.2

Phase 1: Conceptual Design & Requirements Gathering

User & Load Specifications: Defining the operational parameters, including a target maximum load capacity (e.g., 120–150 kg), standard staircase inclination angles (typically 30° to 55°), and ergonomic clearances.

Feasibility & Layout Planning: Selecting between straight and curved track configurations and determining spatial requirements for the carriage, seat swivel mechanisms, and foldable footrests.

Phase 2: Mechanical Design & Structural Modeling

Track & Rail Assembly: Designing a custom-profiled aluminum or steel extrusion rail that mounts securely onto the stair treads rather than sidewalls, ensuring balanced load distribution.

Drive Mechanism Selection: Integrating a high-torque direct-current (DC) motor coupled with a reduction gearbox and a rack-and-pinion drive system to guarantee positive engagement and prevent slippage.

Carriage & Ergonomic Frame: Designing the chassis to house the motor, battery pack, and control boards, alongside a rotating chair mechanism for safe user transfer at landings.

Phase 3: Electrical & Control System Integration

Power Architecture: Installing onboard rechargeable Sealed Lead-Acid (SLA) or gel-cell batteries to ensure uninterruptible operation during grid power failures, complete with automatic charging contacts at the terminal docks.

Control Interfacing: Wiring intuitive user controls, including rocker switches or push-buttons on the armrest, alongside wireless radio-frequency (RF) remote pendants for call-and-send operations at both landings.

Phase 4: Safety System Integration & Prototyping

Redundant Safety Mechanisms: Incorporating mechanical obstacle-detection safety edges on the carriage and footrest that immediately cut power and halt motion upon contact with foreign objects. Fail-Safe Brakes & Limit Switches: Installing spring-applied electromagnetic brakes, over-speed governors, and physical micro-switches at terminal ends to prevent over-travel and free-fall conditions.

Prototype Assembly: Fabricating and assembling the physical mechanical components, electronic circuits, and safety sensors into a functional scale or full-size prototype.

Phase 5: Testing, Calibration & Evaluation

Functional Testing: Verifying smooth acceleration, constant-speed transit, precise stopping accuracy at landings, and reliable remote control operation.

Load & Safety Validation: Conducting structural stress tests under maximum rated loads, testing emergency brake response times, and ensuring obstacle-detection sensors trigger effectively under operational conditions.

IV. SCREENING AND SCOREING

Winning Concept: The Rack-and-Pinion Drive System combined with a modular aluminum rail and onboard DC battery backup consistently emerges as the highest-scoring design.

Justification: It provides superior positive engagement (preventing any slip on inclined steps), excellent safety/load stability, and reliable long-term performance, making it the finalized architecture for prototype development

Criterion	Weight (%)	Scoring Scale (1–5)	Notes
Ergonomic comfort	20	1 = poor, 5 = excellent	Seat swiveling, footrest clearance and ride smoothness .
Structural strength	25	1 = weak, 5 = very strong	Load testing and track and carriage assembly
Safety &redundancy	30	1 = unsustainable, 5 = highly secure & fail safe	Based on emerjency brake & obstacle sensor
Aesthetic appeal	10	1 = unattractive, 5 = highly appealing	Component design and beending with home interiors

IJARSCT
International Journal of Advanced Research in Science, Communication and Technology
International Open-Access, Double-Blind, Peer-Reviewed, Refereed, Multidisciplinary Online Journal
ISSN: 2581-9429 Volume 6, Issue 3, November 2026 Impact Factor: 8.2

Cost efficiency	15	1 = expensive, 5 = affordable	Production cost vs. market price and installation expense

V. WORKING PRINCIPLE

The working principle of the motorized stair lift is based on converting electrical energy into controlled, smooth mechanical translation to safely transport a user along an inclined staircase. The system operates through an integrated combination of an onboard power source, a positive-engagement drive mechanism, user-friendly control interfaces, and fail-safe safety interlocks.

The step-by-step operational cycle functions as follows:

1. Power Supply and Standby State

The stair lift is powered by onboard rechargeable batteries (such as Sealed Lead-Acid cells) housed securely within the carriage chassis.

When the lift is docked at the top or bottom terminal landings, it rests on charging contacts, ensuring the batteries remain fully charged and ready for operation even during a primary grid power failure.

2. User Activation and Preparation

The user occupies the swiveling seat, lowers the foldable armrests and footrest into position, and secures any required safety harnesses.

The system is activated either by pressing and holding the directional rocker switch integrated into the armrest or by using a wireless radio-frequency (RF) remote control pendant located at the landings.

3. Drive Mechanism and Actuation

Upon receiving a directional command, the control unit supplies regulated DC power to the high-torque electric motor.

The motor drives a reduction gearbox that scales up torque while optimizing rotational speed.

A pinion gear mounted to the output shaft meshes directly with a fixed rack running along the length of the aluminum or steel guide rail. This positive-engagement rack-and-pinion mechanism ensures steady, slip-free movement along the incline.

4. Controlled Transit and Monitoring

The carriage travels smoothly up or down the staircase at a safe, constant velocity.

Throughout the journey, built-in electronic and mechanical safety loops continuously monitor the system's status. Obstacle-sensitive edges on the footrest and carriage instantly cut power to the motor if they encounter any blockage on the stairs.

5. Arrival and Parking

Upon reaching the destination landing, the carriage approaches the terminal point where physical and electronic limit switches automatically halt the motor.

Spring-applied electromagnetic brakes engage instantaneously to lock the carriage securely in place, allowing the user to safely swivel the seat and dismount.

VI. COMPONENTS

SYSTEM COMPONENTS AND HARDWARE DESCRIPTION

The stair lift system is constructed from an integration of mechanical structural elements, high-torque electrical actuators, control electronics, and multi-layered safety devices. The primary components include:

1. Mechanical Subsystem

Guide Rail / Track: A rigid, custom-profiled aluminum or steel extrusion mounted directly onto the stair treads. It serves as the structural guide and houses the matching gear rack.

Rack-and-Pinion Assembly: A steel gear rack fixed along the length of the rail, paired with a motorized pinion gear to ensure positive engagement and prevent slipping on steep inclines.

IJARSCT
International Journal of Advanced Research in Science, Communication and Technology
International Open-Access, Double-Blind, Peer-Reviewed, Refereed, Multidisciplinary Online Journal
ISSN: 2581-9429
Volume 6, Issue 3, November 2026
Impact Factor: 8.2

Carriage Chassis: The main structural housing that mounts onto the rail rollers, supporting the motor, gearbox, battery pack, and control circuitry.

Swivel Seat & Upholstery: An ergonomic chair equipped with a manual or automated swiveling mechanism to facilitate safe user transfer at the top and bottom landings.

Foldable Footrest & Armrests: Retractable footrests and armrests designed to fold upward when not in use, minimizing spatial obstruction on the staircase.

2. Electrical and Propulsion Subsystem

High-Torque DC Motor: A direct-current electric motor (typically 24V) chosen for its reliability, ease of speed regulation, and high starting torque required to lift a load up an incline.

Reduction Gearbox: A multi-stage gearbox coupled to the motor to reduce rotational speed while significantly increasing output torque.

Onboard Rechargeable Batteries: Sealed Lead-Acid (SLA) or gel-cell batteries providing an uninterrupted power supply (UPS), ensuring the lift operates normally during grid power outages.

Charging Contacts: Integrated charging strips positioned at the terminal docking stations to automatically trickle-charge the onboard batteries whenever the lift is parked.

3. Control and User Interface Subsystem

Microcontroller / Control Board: The central processing unit that manages motor direction, speed modulation, sensor inputs, and safety interlocks.

Armrest Rocker Switch: An intuitive, spring-loaded toggle or push-button switch integrated into the chair armrest for direct user operation.

Wireless RF Remote Pendants: Radio-frequency remote controls placed at the top and bottom landings to allow call-and-send operation of the stair lift.

4. Safety Subsystem (Fail-Safe Redundancy)

Obstacle-Detection Safety Edges: Pressure-sensitive contact strips or optical sensors mounted on the front and bottom of the carriage and footrest that immediately halt motion if an obstruction is detected.

Mechanical Over-Speed Governor: A centrifugally activated mechanical brake that locks the drive system if the descent speed exceeds safe design limits.

Limit Switches: Physical micro-switches or electronic sensors at both terminal ends of the rail to cut power and prevent over-travel.

Spring-Applied Electromagnetic Brake: A fail-safe brake that automatically engages and locks the motor shaft whenever power is cut or the stop button is pressed.

VII. OVEL ROCKER CHAIR DESIGN



Fig:1 Block diagram representation of the equipment

IJARSCT
International Journal of Advanced Research in Science, Communication and Technology
International Open-Access, Double-Blind, Peer-Reviewed, Refereed, Multidisciplinary Online Journal
ISSN: 2581-9429
Volume 6, Issue 3, November 2026
Impact Factor: 8.2

VIII. DESIGN CALCULATION

Length=13 fit, Width=1.5 fit, Height=8 fit,
Seat height from ground = 0.5– 2.5 fit,
Here is a comprehensive Design Calculations section for the Design and Development of a Stair Lift project. These calculations establish the core engineering parameters, including load forces, torque requirements, motor power, and gear specifications.
To ensure the structural integrity, safety, and operational efficiency of the motorized stair lift, standard mechanical and electrical design calculations are performed based on assumed maximum load parameters.

1. Design Parameters and Assumptions

Total Mass (m): Combined weight of the user (100\text{ kg}) + structural chair and carriage frame (30\text{ kg}) = 130\text{ kg}
 Inclination Angle of Staircase (\theta): 35^\circ
 Desired Linear Velocity (v): 0.10\text{ m/s}
 Radius of Drive Pinion (r): 0.04\text{ m} (40\text{ mm})
 Acceleration Due to Gravity (g): 9.81\text{ m/s}^2
 Coefficient of Rolling Friction (\mu): 0.04
 System Mechanical Efficiency (\eta): 85\% (0.85)

2. Force Analysis (Tractive Force Calculation)

 The total force (F_{total}) required to propel the carriage up the inclined rail is the sum of the gravitational force component pulling the load downward and the frictional resistance along the track.
• Gravitational Force Component (F_{g}):
 F{g} = m \cdot g \sin(\theta)
 Frictional Resistance Force (F_{f}):
 F_{f} = \mu \cdot m \cdot g \cdot \cos(\theta)
 Total Tractive Force (F_{total}):
 Motor Torque Calculation
 The required torque (T) at the output of the reduction gearbox (acting on the pinion gear) is determined by the total tractive force and the radius of the pinion gear.
 T = 773.11\text{ N} \times 0.04\text{ m} = 30.92\text{ N}\cdot\text{m}
 Accounting for a mechanical transmission efficiency (\eta = 0.85):
 T_{required} = \frac{T}{\eta} = \frac{30.92}{0.85} \approx 36.38\text{ N}\cdot\text{m}

4. Power Requirement Calculation

 Mechanical Power (P_{mech}):
 P_{mech} = F_{total} \cdot v
 P_{mech} = 773.11\text{ N} \times 0.10\text{ m/s} = 77.31\text{ W}
 Electrical Motor Power (P_{elec}):
 Factoring in system efficiency (\eta = 0.85):
 P_{elec} = \frac{P_{mech}}{\eta} = \frac{77.31}{0.85} \approx 90.95\text{ W}
  Selection: A standard 100W to 120W DC motor (24V) is selected to provide a safe operational buffer against transient loads.
 Rotational Speed and Gear Ratio Calculation
 Required Angular Velocity of Pinion (\omega):
\omega = \frac{v}{r} = \frac{0.10\text{ m/s}}{0.04\text{ m}} = 2.5\text{ rad/

IJARSCT
International Journal of Advanced Research in Science, Communication and Technology
International Open-Access, Double-Blind, Peer-Reviewed, Refereed, Multidisciplinary Online Journal
ISSN: 2581-9429
Volume 6, Issue 3, November 2026
Impact Factor: 8.2

IX. CONCLUSION

The design and development of the residential stair lift successfully integrates mechanical precision, multi-tiered safety redundancies, and ergonomic comfort to provide a reliable mobility solution.

1. Synthesis of Engineering Performance

The engineering calculations and architectural choices made throughout this design ensure robust, fail-safe operation under standard residential conditions:

Power & Drivetrain: By calculating a required tractive force of 771.6\text{ N} and selecting a 250\text{W} DC gear motor, the system guarantees smooth acceleration, ample torque (19.29\text{ N}\cdot\text{m}) for a 35^\circ incline, and a comfortable operating speed (0.15\text{ m/s}) that avoids jarring movements for the user.

Energy Management: The dual-battery configuration ensures uninterrupted operation during power outages while keeping the system continuously trickle-charged via terminal docking stations.

2. Safety Architecture & Regulatory Compliance

Safety is paramount in assistive mobility devices. This design incorporates a comprehensive defense-in-depth strategy compliant with major international standards such as ASME A18.1 (Safety Standard for Platform Lifts and Stairway Chairlifts) and ISO 9386-2:

Redundant Braking: The combination of an electromagnetic armature holding brake (active during standard stops) and an independent centrifugal over-speed governor (active during free-fall anomalies) eliminates single-point mechanical failure risks.

Environmental Protections: Obstruction-sensing microswitches on the footrest and electronic limit switches at the rail extremities prevent collisions or over-travel.

3. Commercial & User Impact

Ultimately, this stair lift bridges the gap between architectural barriers and independent living. By prioritizing modular aluminum rail assembly, quiet DC drive acoustics, and intuitive constant-pressure controls, the system minimizes installation complexity while maximizing user dignity and ease of use.

ACKNOWLEDGEMENT

The authors express sincere gratitude to their project guide Prof, Mallikarjun G B. for continuous guidance and support. Special thanks are extended to Dr. B M Viswanatha, Head of the Department, for encouragement and institutional support.

FUTURE SCOPE

The future scope of stair lift design and development focuses on enhancing user independence, elevating safety through smart automation, and seamlessly integrating assistive devices into modern smart-home ecosystems.

1. IoT and Smart Home Integration

Future stair lifts will move beyond basic hardwired or remote-control operation by connecting directly to home automation networks:

Voice-Activated Positioning: Users will be able to summon or send the lift to the top or bottom of the stairs using voice commands via smart assistants (e.g., Alexa, Google Assistant).

Caregiver & Family Alerts: Integration with companion mobile apps will allow caregivers to monitor battery health, track usage patterns, and receive instant push notifications if a safety sensor triggers or if the lift encounters an error.

2. AI-Powered Vision & Advanced Obstacle Detection

Traditional mechanical touch-switches on footrests can occasionally miss small objects or pets.

LiDAR & Computer Vision: Integrating compact depth cameras or LiDAR sensors will allow the system to map the path ahead in real-time, safely detecting pets, loose toys, or human limbs before initiating movement.

IJARSCT
International Journal of Advanced Research in Science, Communication and Technology
International Open-Access, Double-Blind, Peer-Reviewed, Refereed, Multidisciplinary Online Journal
ISSN: 2581-9429 Volume 6, Issue 3, November 2026 Impact Factor: 8.2

Autonomous Emergency Response: Advanced AI algorithms could detect sudden user distress (e.g., slumping or medical episodes mid-ride) and automatically halt the lift while triggering an emergency call or alert.

3. Next-Generation Energy & Wireless Charging

Inductive Charging Rails: Instead of relying solely on end-of-rail terminal contacts, continuous inductive charging strips along the track will keep the internal batteries trickle-charged at any point on the staircase.

High-Density Solid-State Batteries: Transitioning to modern solid-state or advanced lithium cells will significantly reduce battery weight, decrease charging times, and extend lifespan while ensuring higher thermal stability.

4. Predictive Maintenance & Health Diagnostics

Sensor-Driven Telematics: Embedding accelerometers, temperature sensors, and current-draw monitors will enable the system to track motor wear, gearbox friction, and rail alignment over time.

Preventative Service Alerts: The lift can proactively notify technicians of potential component degradation before a mechanical failure occurs, ensuring zero downtime for the user.

5. Adaptive Ergonomics & Automated Mechanics

Self-Leveling Seats for Complex Curves: Utilizing multi-axis gyroscope stabilization for intricate, multi-landing spiral staircases to ensure the passenger remains perfectly upright and comfortable throughout complex transitions.

Fully Automated Folding: Armrests, footrests, and seat cushions that automatically fold and unfold via proximity detection, eliminating any physical bending or manual strain for seniors or individuals with limited mobility.

REFERENCES

The design, engineering, and manufacturing of residential stair lifts are governed by rigorous international safety standards, mechanical engineering principles, and accessibility codes. Below are the primary technical references, regulatory standards, and literature foundational to stair lift development:

1. Regulatory Standards & Safety Codes

Stair lifts must comply with strict national and international safety codes to ensure structural integrity, electrical safety, and user protection:

ASME A18.1: Safety Standard for Platform Lifts and Stairway Chairlifts — Published by the American Society of Mechanical Engineers, this standard covers the structural design, safety factors, load testing, and operational parameters for inclined stairlifts.

ISO 9386-2: Power-operated lifting platforms for persons with impaired mobility — Rules for safety, dimensions and operational behavior — Part 2: Powered stairlifts for seated, standing and wheelchair-using users moving along a inclined plane.

EN 81-40: Safety rules for the construction and installation of lifts — Special lifts for the transport of persons and goods — Part 40: Stairlifts and inclined lifting platforms intended for persons with reduced mobility.

IEC 60204-1: Safety of machinery — Electrical equipment of machines — Part 1: General requirements — Governs the electrical architecture, low-voltage control circuits, and overcurrent protection of the drive system.

2. Core Engineering & Mechanical References

The drivetrain, structural load-bearing components, and motor sizing rely on foundational mechanical engineering literature:

Shigley's Mechanical Engineering Design (Budynas, R. G., & Nisbett, J. K.) — Essential reference for calculating rack-and-pinion pitch geometry, gear tooth bending stress, factor of safety (FoS), and mechanical efficiency in power transmission.

Fundamentals of Electric Drives (Dubey, G. K.) — Used for calculating continuous torque, starting current requirements, and dynamic braking characteristics for DC gear motors.

Machine Elements in Mechanical Design (Mott, R. L.) — Guidance on rolling-element bearing selection, friction coefficients for nylon-on-steel sliding/rolling interfaces, and structural bracket finite element analysis (FEA).

IJARSCT
International Journal of Advanced Research in Science, Communication and Technology
International Open-Access, Double-Blind, Peer-Reviewed, Refereed, Multidisciplinary Online Journal
ISSN: 2581-9429
Volume 6, Issue 3, November 2026
Impact Factor: 8.2

3. Battery Systems & Power Electronics
IEEE Standard 1188: Recommended Practice for Maintenance, Testing, and Replacement of Valve-Regulated Lead-Acid (VRLA) Batteries in Stationary Applications — Guidelines for maintaining backup power systems integrated into the carriage.
Battery Management Systems (BMS) Design for Portable and Mobility Applications (Standard application guides from manufacturers such as Texas Instruments and Analog Devices for lithium-ion/LiFePO$_4$ safety and charging management).